

AirTrunk SYD 2 - Apollo Place Data Centre - SSD-67407231

Conditions Compliance Table - Construction Environmental Management Plan

Date of Submission **28/07/2026**

AW EDWARDS

 **AIRTRUNK**

DATE SUBMITTED	No:	Subject	Condition Content:	COMPLIANCE
27/05/2026	B7	Construction Noise and Vibration Management Plan	The Applicant must prepare a Construction Noise and Vibration Management Plan (CNVMP) for the development to the satisfaction of the Planning Secretary. The CNVMP must form part of the development's CEMP in accordance with condition C2 and must : (a) be prepared by a suitably qualified and experienced noise expert; (b) include evidence of consultation with TfNSW and Transurban; (c) describe the procedures to: (i) refine the construction methodology and work schedule to minimise construction noise and vibration impacts ; (ii) achieve the noise management levels in ICNG (as may be updated or replaced from time to time); (iii) achieve the vibration criteria specified in condition B4; and (iv) carry out noise and vibration monitoring, including details of the associated frequency/duration; (d) include: (i) a vibration trigger action response plan developed in consultation with TfNSW and Transurban; (ii) management and mitigation measures, including any described in Appendix 2 of this consent; (iii) a description of measures to be implemented to manage high noise or vibration generating works such as piling, rock breaking and vibratory compaction, in close proximity to sensitive receivers; (iv) strategies that have been developed in consultation with the directly adjoining properties for managing noise and vibration impacts, such as any alternative construction methods with lower source intensity levels and provision for respite periods; (v) a description of the community consultation undertaken to develop the strategies in (d)(iii) above and (d)(i) above; and (vi) a complaints management system to be implemented for the duration of construction.	Compliant Refer to Appendix B of the CEMP - Construction Noise and Vibration Monitoring Plan prepared by Renzo Tonin
27/05/2026	B8	Construction Noise and Vibration Management Plan	The Applicant must: (a) not commence construction of the development until the CNVMP required by condition B7 is approved by the Planning Secretary; and (b) implement the most recent version of the CNVMP approved by the Planning Secretary for the duration of construction.	Compliant AWE acknowledge construction cannot commence until Condition B7 is approved by the Planning Secretary
29/05/2026	B11	Dilapidation Report – Private Land	During the following phases of development : (a) prior to the commencement of construction; and	Compliant AWE acknowledge Dilapidation reports are compliant with condition B11 a)
27/05/2026	B26	Construction Traffic Management Plan	Prior to the commencement of construction, the Applicant must prepare a Construction Traffic Management Plan (CTMP) for the development to the satisfaction of the Planning Secretary. The plan must form part of the CEMP required by condition C2 and must: (a) be prepared by a suitably qualified and experienced person(s); (b) be prepared in consultation with Council; (c) detail the measures that are to be implemented to ensure road safety and network efficiency during construction; (d) detail heavy vehicle routes, access and parking arrangements , and describe the procedures to ensure compliance with condition s B24 and B25; (e) provide details of any oversized vehicles required for construction; (f) provide details of traffic control measures (such as an escort or other suitable traffic control measure) to manage the movement of oversized vehicles along public roads; (g) include a Driver Code of Conduct to: (i) minimise the impacts of earthworks and construction on the local and regional road network; (ii) minimise conflicts with other road users; (iii) minimise road traffic noise; and (iv) ensure truck drivers use specified routes; (h) include a program to monitor the effectiveness of these measures; and (i) if necessary, detail procedures for notifying residents and surrounding businesses of any potential disruptions to routes.	Compliant Refer to Appendix C of the CEMP - Construction Traffic Management Plan prepared by TTPA. Evidence of Lane Cove Council Consultation has been included in this report
27/05/2026	B27	Construction Traffic Management Plan	The Applicant must: (a) not commence construction until the CTMP required by condition B26 is approved by the Planning Secretary; and (b) implement the most recent version of the CTMP approved by the Planning Secretary for the duration of construction.	Compliant AWE acknowledge construction cannot commence until Condition B26 is approved by the Planning Secretary
27/05/2026	B59	Contamination Unexpected Finds	Prior to the commencement of construction, the Applicant must prepare an unexpected contamination finds procedure to ensure that potentially contaminated material is appropriately managed. The procedure must form part of the of the CEMP in accordance with condition C2 and must ensure any material identified as contaminated is managed in accordance with the POEO Act and its associated regulations. Details of the final management approach and the results of any associated testing must be submitted to the Planning Secretary within six weeks of the Applicant becoming aware of the contamination find (or as otherwise to by the Planning Secretary).	Compliant Refer to Appendix E of the CEMP - Unexpected Finds Protocol prepared by Senversa
27/05/2026	B60	Remediation Works	The Applicant must ensure the remediation works for the development are undertaken by a suitably qualified and experienced consultant(s) in accordance with the approved Remedial Action Plan (prepared by Senversa Pty Ltd , dated 27 June 2024) and relevant guidelines produced or approved under the Contaminated Land Management Act 1997.	Compliant Refer to Appendix F of the CEMP - Remediation Action plan prepared by Senversa
27/05/2026	C1	Environmental Management Plan Requirements	Management plans required under this consent must be prepared in accordance with relevant guidelines, and include: (a) a condition compliance table for that plan; (b) detailed baseline data (where required) ; (c) details of: (i) the relevant statutory requirements (including any relevant approval, licence or lease conditions); (ii) any relevant limits or performance measures and criteria; and (iii) the specific performance indicators that are proposed to be used to judge the performance of, or guide the implementation of, the development or any management measures; (d) a description of the measures to be implemented to comply with the relevant statutory requirements, limits, or performance measures and criteria; (e) a program to monitor and report on the: (i) impacts and environmental performance of the development; and (ii) effectiveness of the management measures set out pursuant to paragraph (d) above; (f) a contingency plan to manage any unpredicted impacts and their consequences and to ensure that ongoing impacts reduce to levels below relevant impact assessment criteria as quickly as possible; (g) a program to investigate and implement ways to improve the environmental performance of the development over time; (h) a protocol for managing and reporting any: (i) incident and any non -compliance (specifically including any exceedance of the impact assessment criteria and performance criteria); (ii) complaint; (iii) failure to comply with statutory requirements; and (i) a protocol for periodic review of the plan. <i>(i) a protocol for periodic review of the plan.</i> Note: The Planning Secretary may waive some of these requirements if they are unnecessary or unwarranted for particular management plans	Compliant CEMP Report has been prepared in accordance with C1.
27/05/2026	C2	Construction Environmental Management Plan	The Applicant must prepare a Construction Environmental Management Plan (CEMP) for the development in accordance with the requirements of condition C1 and to the satisfaction of the Planning Secretary.	Compliant CEMP Report has been prepared in accordance with C2.
27/05/2026	C3	Construction Environmental Management Plan	As part of the CEMP required under condition C2 of this consent, the Applicant must include the following: (a) details of the community consultation and complaints handling procedure to be implemented during construction; (b) Construction Noise and Vibration Management Plan (see condition B7); (c) Construction Traffic Management Plan (see condition B26); (d) erosion and sediment control plan(s) (see condition B39); (e) Unexpected Contamination Finds Procedure (see condition B59); and (f) Remedial Action Plan (see condition B60).	Compliant CEMP Report has been prepared in accordance with C3. Refer to Appendix for relevant information: Appendix A - Community Consultation & Complaints Handling Strategy Appendix B - Construction Noise and Vibration Management Plan Appendix C - Construction Traffic Management Plan Appendix D - Erosion and Sediment Control Plan Appendix E - Unexpected Finds Protocol Appendix F - Remediation Action Plan
27/05/2026	C4	Construction Environmental Management Plan	The Applicant must: (a) not commence construction of the development until the CEMP required under condition C2 is approved by the Planning Secretary; and (b) carry out the construction of the development in accordance with the CEMP approved by the Planning Secretary (and as revised and approved by the Planning Secretary from time to time).	Compliant AWE acknowledge construction cannot commence until Condition C2 is approved by the Planning Secretary

DATE SUBMITTED	No:	Subject	Condition Content:	COMPLIANCE
9/07/2026	C8	Construction Environmental Mangement Plan	Prior to the commencement of construction of any works associated with any modification to this consent, or within three months of: (a) the submission of an incident report under condition C10; (b) the submission of a Compliance Report under condition C14; (c) the submission of a Back-up Generator Incident Report under condition C17; (d) the approval of any modification of the conditions of this consent ; or (e) the issue of a direction of the Planning Secretary under condition A2(b) which requires a review, the strategies, plans and programs required under this consent must be reviewed, and the Planning Secretary must be notified in writing of the outcomes of any review.	Compliant AWE acknowledge the commitment to address the requirements as stipulated under condition C8 to the satisfaction of the Planning Secretary where relevant and appropriate.
9/07/2026	C9	Construction Environmental Mangement Plan	If identified as part of the review process (see condition C8), or considered necessary to improve the environmental performance of the development, the Applicant must ensure the strategies , plans and /or programs required under this consent are revised, to the satisfaction of the Planning Secretary. The revised document(s) must be submitted to the Planning Secretary for approval within six weeks of the review process taking place , or in the case of a modification approving the construction of any works , prior to the commencement of construction of those works, or such other timing as agreed by the Planning Secretary. Note: This is to ensure strategies, plans and programs are updated on a regular basis and to incorporate any recommended measures to improve the environmental performance of the development.	Compliant AWE acknowledge the commitment to address the requirements as stipulated under condition C9 to the satisfaction of the Planning Secretary where relevant and appropriate.
9/07/2026	C10	Construction Environmental Mangement Plan	The Applicant must notify the Department within 24 hours of becoming aware of an incident. The notification must be made via the NSW planning portal (Major Projects) and address details of the incident , including: (a) the date, time and location; (b) a brief description of what occurred and why it has been classified as an incident; (c) a description of what immediate steps were taken in relation to the incident; and (d) identifying a contact person for further communication regarding the incident.	Compliant AWE acknowledge the notification requirement with regards to incident reporting. CEMP has been updated, refer to Section 6.2.2 of the CEMP document.
9/07/2026	C11	Construction Environmental Mangement Plan	The Applicant must provide the Department with a subsequent incident report in accordance with the requirements set out in Appendix 3 of this consent .	Compliant AWE acknowledge the notification requirement with regards to incident reporting. CEMP has been updated, refer to Section 6.2.2 of the CEMP document.
9/07/2026	C12	Construction Environmental Mangement Plan	Within seven days of becoming aware of any non -compliance, the Applicant must notify the Department of the non-compliance , in writing , via the NSW planning portal (Major Projects).	Compliant AWE acknowledge the notification requirement with regards to incident reporting. CEMP has been updated, refer to Section 6.2.2 of the CEMP document.
9/07/2026	C13	Construction Environmental Mangement Plan	A non -compliance notification submitted under condition C12 must identify the development (including the development application number and name), set out the condition of this consent that the development is non-compliant with, why it does not comply, the reasons for the non -compliance (if known), and what actions have been undertaken, or will be undertaken, and when, to address the non -compliance. Note: A non -compliance which has been notified as an incident does not need to also be notified as a non-compliance.	Compliant AWE acknowledge the notification requirement with regards to incident reporting. CEMP has been updated, refer to Section 6.2.2 of the CEMP document.
9/07/2026	C18	Construction Environmental Mangement Plan	Any condition of this consent that requires the carrying out of monitoring or an environmental audit, whether directly or by way of a plan, strategy or program, is taken to be a condition requiring monitoring or an environmental audit under Division 9.4 of Par t 9 of the EP&A Act. This includes conditions in respect of incident notification, reporting and response, non -compliance notification , compliance report ing and independent auditing. Note: For the purposes of this condition, as set out in the EP&A Act, “monitoring” is monitoring of the development to provide data on compliance with the consent or on the environmental impact of the development, and an “environmental audit” is a periodic or pa ricular documented evaluation of the development to provide information on compliance with the consent or the environmental management or impact of the development.	Compliant AWE acknowledges monitoring and audit obligations under Division 9.4 of Part 9 of the EP&A Act. The CEMP (page 45 - 47) details these requirements across relevant consent conditions through dedicated monitoring plans, strategies, and programs.
9/07/2026	C19	Construction Environmental Mangement Plan	At least 48 hours before the commencement of construction of the development and for the life of the development (or such other time as agreed by the Planning Secretary) , including during remediation, the Applicant must: (a) make the following information and documents (as they are obtained or approved) publicly available on its website: (i) the documents referred to in condition A2 of this consent; (ii) all current statutory approvals for the development; (iii) all approved strategies, plans and programs required under the conditions of this consent with the exception of any hazard and risk related studies ; (iv) regular reporting on the environmental performance of the development in accordance with the reporting requirements in any plans or programs approved under the conditions of this consent; (v) a comprehensive summary of the monitoring results of the development, reported in accordance with the specifications in any conditions of this consent, or any approved plans and programs; (vi) a summary of the current stage and progress of the development; (vii) contact details to enquire about the development or to make a complaint; (viii) a complaints register, updated quarterly ; (ix) the Compliance Report of the development; (x) any other matter required by the Planning Secretary; and (b) keep such information up to date, to the satisfaction of the Planning Secretary.	Compliant AWE acknowledge the conditions related to management of information in line with condition C19. Section 5.2 of the CEMP has been updated accordingly addressing these requirements. This is also addressed within the Community Consultation and Complaints Handling Strategy (CCCHS).
9/07/2026	B1	Construction Environmental Mangement Plan	The Applicant must comply with the hours detailed in Table 2 below . Construction Monday – Friday 7 am to 6 pm Saturday - 8 am to 1 pm	Compliant AWE acknowledge compliance to the hours of work as set out in condition B1.
9/07/2026	B2	Construction Environmental Mangement Plan	Works outside of the hours identified in condition B1 may be undertaken in the following circumstances: (a) works that are inaudible at the nearest sensitive receivers; (b) works agreed to in writing by the Planning Secretary; (c) for the delivery of materials required outside these hours by the NSW Police Force or other authorities for safety reasons; or (d) where it is required in an emergency to avoid the loss of lives, property or to prevent environmental harm.	Compliant AWE acknowledge compliance to the hours of work as set out in condition B2. This process is also noted within the CEMP and CNVMP .
9/07/2026	B3	Construction Environmental Mangement Plan	The development must be constructed to achieve the construction noise management levels detailed in the ICNG (as may be updated or replaced from time to time). All feasible and reasonable noise mitigation measures must be implemented and any activities that could exceed the construction noise management levels must be identified and managed in accordance with th e management and mitigation measures in Appendix 2 of this consent and the development’s CNVMP (see condition B7).	Compliant AWE acknowledge compliance to the construction noise management levels as noted within the CEMP and CNVMP .
9/07/2026	B4	Construction Environmental Mangement Plan	Vibration caused by construction at any structure outside the site must be limited to: (a) for structural damage, the latest version of DIN 4150 -3 (2016 -12) Vibration in Buildings – Part 3: Effects on Structures (German Institute for Standardisation, 2016) and BS 7385 -2 Evaluation and measurement for vibration in buildings Guide to damage levels from groundborne vibration (British Standards Institution, 1993); and (b) for human exposure, the acceptable vibration values set out in the Environmental Noise Management Assessing Vibration: a technical guideline (DEC, 2006) (as may be updated or replaced from time to time) .	Compliant AWE acknowledge compliance to the construction noise management levels as noted within the CEMP and CNVMP .
9/07/2026	B5	Construction Environmental Mangement Plan	Vibratory compactor , rock hammer or piling equipment must not be used closer than 30 metres from any structure at 5 Sirius Road (Lot 5 in DP 241786) , unless vibration monitoring confirms compliance with the vibration criteria specified in condition B4.	Compliant AWE acknowledge compliance to the construction vibration levels as noted within the CNVMP. AWE also acknowledge the condition set out under B5 that Vibratory compactor , rock hammer or piling equipment must not be used closer than 30 metres from any structure at 5 Sirius Road (Lot 5 in DP 241786) , unless vibration monitoring confirms compliance with the vibration criteria specified in condition B4.
9/07/2026	B6	Construction Environmental Mangement Plan	The limits in conditions B4 and B5 apply unless otherwise outlined in the development’s CNVMP, approved as part of the CEMP required by condition C2 of this consent.	Compliant AWE acknowledge compliance to the construction vibration levels as noted within the CNVMP as part of condition C2.
9/07/2026	B7 (d)(i)	Construction Environmental Mangement Plan	(d) include: (i) a vibration trigger action response plan developed in consultation with TfNSW and Transurban;	Compliant AWE confirm the CNVMP has been issued to TU and TfNSW following a meeting on 5/3/2026. Evidence of this meeting has been provided through the form of a meeting invite and attendees including Tracy Gowen of Renzo Tonin (Author of the CNVMP). A Trigger Action Response Plan has also been prepared.
10/07/2026	B7 (d)(iv)	Construction Environmental Mangement Plan	(iv) strategies that have been developed in consultation with the directly adjoining properties for managing noise and vibration impacts, such as any alternative construction methods with lower source intensity levels and provision for respite periods;	Compliant To address condition B7, AWE have prepared a Community Consultation and Complaints Handling Strategy (CCCHS). Refer to Section 5.2 and Appendix B of the CCCHS.

DATE SUBMITTED	No:	Subject	Condition Content:	COMPLIANCE
10/07/2026	B7 (d)(v)	Construction Environmental Mangement Plan	(v) a description of the community consultation undertaken to develop the strategies in (d)(iii) above and (d)(i) above; and	Compliant To address condition B7, AWE have prepared a Community Consultation and Complaints Handling Strategy (CCCHS). Refer to Section 5.2 and Appendix B of the CCCHS.
10/07/2026	B7 (d)(vi)	Construction Environmental Mangement Plan	(vi) a complaints management system to be implemented for the duration of construction.	Compliant To address condition B7, AWE have prepared a Community Consultation and Complaints Handling Strategy (CCCHS). Refer to Section 5.2 and Appendix B of the CCCHS.
10/07/2026	B9 (c)	Construction Environmental Mangement Plan	(c) enter into an interface agreement , with LCT-MRE Pty Ltd , if deemed necessary by TfNSW or Transurban ;	Compliant AWE acknowledge compliance to condition B9 (c). Interface agreement currently in negotiation with Airtrunk and Transurban.
10/07/2026	B11 (a)	Construction Environmental Mangement Plan	During the following phases of development : (a) prior to the commencement of construction; and	Compliant AWE acknowledge compliance to the dilapidation report requirements. AWE has notified and already completed dilapidation reports for landowners at 7 Sirius Road (Lot 42 DP 571838), 9 Sirius Road (Lot 3 DP 241786) and 3 Apollo Place (Lot 8 DP 241877).
10/07/2026	B34	Construction Environmental Mangement Plan	The Applicant must not commence construction of the development (except for construction of preliminary works that are outside the scope of the fire -related reports or studies) until the FSS required by condition B33 has been approved by FRNSW and the Planning Secretary.	Compliant AWE acknowledge compliance to the fire related reports or studies. dilapidation report requirements. It is noted that preliminary construction works outside of the scope of the fire related reports or studies will commence. Any construction related to fire related reports or studies will not commence until the condition is satisfied.
11/07/2026	B45	Construction Environmental Mangement Plan	If any item or object of Aboriginal heritage significance is identified on site: (a) all work in the immediate vicinity of the suspected Aboriginal item or object must cease immediately; (b) a 10 m wide buffer area around the suspected item or object must be cordoned off; and (c) Heritage NSW must be contacted immediately.	Compliant AWE acknowledge compliance to condition B45 with regards to Aboriginal heritage significance.
11/07/2026	B46	Construction Environmental Mangement Plan	Work in the immediate vicinity of the Aboriginal item or object may only recommence in accordance with the provisions of Part 6 of the National Parks and Wildlife Act 1974 .	Compliant AWE acknowledge compliance to condition B46 with regards to Aboriginal heritage significance.
28/07/2026	B49	Biodiversity Biodiversity Offset	Prior to any clearing or construction works for the development, the Applicant must purchase and retire two (2) ecosystem credits to offset the removal of the Sydney Coastal Sandstone Foreshores Forest (Plant Community Type 3594) at the site. The two (2) ecosystem credits must be retired in accordance with the requirements of the Biodiversity Offsets Scheme and the Biodiversity Conservation Act 2016 .	Compliant AWE acknowledge that the Client (AirTrunk) are in the process of complying with this condition and arranging payments. This will be provided to the Principal Certifier as part of the Construction Certificate approval
28/07/2026	B50	Biodiversity Biodiversity Offset	The requirement to retire two (2) ecosystem credits (see condition B49) may be satisfied by payment to the Biodiversity Conservation Fund of an amount equivalent to the number and classes of ecosystem credits , as calculated by the Biodiversity Offsets Payment Calculator.	Compliant AWE acknowledge that the Client (AirTrunk) are in the process of complying with this condition and arranging payments. This will be provided to the Principal Certifier as part of the Construction Certificate approval
28/07/2026	B51	Biodiversity Biodiversity Offset	Prior to undertaking any clearing or construction works for the development, the Applicant must provide the Planning Secretary with evidence that: (a) the retirement of two (2) ecosystem credits has been completed in accordance with condition B49; or (b) a payment has been made to the Biodiversity Conservation Fund in accordance with condition B50.	Compliant AWE acknowledge that the Client (AirTrunk) are in the process of complying with this condition and arranging payments. This will be provided to the Principal Certifier as part of the Construction Certificate approval
12/07/2026	B62	Construction Environmental Mangement Plan	The Applicant must ensure that any asbestos encountered during the remediation and construction works for the development is monitored, handled, transported and disposed of by appropriately qualified and licensed contractors in accordance with the requirements of SafeWork NSW and relevant guidelines, including: (a) Work Health and Safety Regulation 2017 ; (b) Code of Practice – How to Manage and Control Asbestos in the Workplace (SafeWork NSW, 2022); (c) Code of Practice – How to Safely Remove Asbestos (SafeWork NSW, 2022); and (d) Protection of the Environment Operations (Waste) Regulation 2014 .	Compliant AWE acknowledge compliance to condition B62 with regards to the potential encounter of any asbestos and associated Code of Practices.
12/07/2026	B65	Construction Environmental Mangement Plan	The Applicant must ensure the lighting associated with the development: (a) complies with the latest version of AS 4282 -2019 - Control of the obtrusive effects of outdoor lighting (Standards Australia, 2019) ; and (b) is mounted, screened and directed in such a manner that it does not create a nuisance to surrounding properties or the public road network.	Compliant AWE acknowledge compliance to condition B65 with regards to lighting used during construction being compliant with AS 4282-2019 .
27/07/2026	B41	Construction Environmental Mangement Plan	The development must comply with section 120 of the POEO Act, which prohibits the pollution of waters, except as expressly provided for in an Environment Protection Licence or in accordance with any applicable regulations under the POEO Act.	Compliant AWE acknowledge the conditions of pollution of waters and is addressed within the key project risks of the CEMP.
27/07/2026	B42(c)	Construction Environmental Mangement Plan	Prior to the commencement of construction of the development 's stormwater management system , the Applicant must finalise the system 's detailed design. The final stormwater management system must: (c) be generally in accordance with the conceptual design in the EIS and Submissions Report ;	Compliant AWE acknowledge the condition set out in B42(c) and confirm the stormwater management system has been designed in accordance with the EIS and submission reports.
27/07/2026	B52	Construction Environmental Mangement Plan	The Applicant must retain and protect Tree ID 2 and ID 4 , identified in the Arboricultural Impact Assessment & Tree Protection Plan prepared by Tree Survey Pty Limited and dated 20 June 2024, throughout the life of the development. These trees are to be protected in accordance with the latest version of Australian Standard 4970:2009 – Protection of Trees on Development . All required tree protection measures must be implemented prior to the commencement of construction works at the site.	Compliant AWE acknowledge the condition as set out under condition B52. Section 5.6.13 – Tree Protection Management of the CEMP has been updated to address all required protection measures.
27/07/2026	A8	Construction Environmental Mangement Plan	The Proponent will ensure that all plant and equipment used on-site, is maintained and operated in proper and efficient manner, and in accordance with relevant Australian Standards.	Compliant AWE acknowledge the condition set out in A8 and confirm that all plant and equipment used on-site will be maintained and operated in a proper and efficient manner, and in accordance with the relevant Australian Standards.
27/07/2026	A9	Construction Environmental Mangement Plan	The Proponent will monitor the state of roadways leading to and from the subject Site, during construction, and will take all necessary steps to clean up any adversely impacted road pavements as directed by the Lane Cove Council.	Compliant AWE acknowledge the condition set out in A9 and confirm measures will be undertaken to monitor the state of roadways leading to and from the subject site, in the form of a dilapidation survey.
27/07/2026	A12	Construction Environmental Mangement Plan	A Soil and Water Management Plan (SWMP) and Erosion and Sediment Control Plan (ESCP), or equivalent, will be implemented for the construction of the proposed development.	Compliant AWE acknowledges Condition A12 and confirms that a Soil and Water Management Plan (SWMP) will be prepared and implemented for the development, in addition to the Erosion and Sediment Control Plan (Appendix D). The SWMP will be completed prior to the commencement of construction works.